



Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Rc.No. 336 / SHP / DM&HO / Medchal / 2025 - 26.

Dated: 28 / 06 / 2025.

It is certified that an inspection team headed by Y. Vijay Kumar, Health Inspector, Medchal Malkajgiri District, from DM&HO Office (Health Department) and Department of Water and Waste Water Examination MPTRI, Sy.No: 342, Near Pragathi Nagar, Opp: JNTU Lane, Kukatpally, Hyd - certified Accredited Laboratory have inspected **St. Martin's School**, Located at Sy.No: 243, Shilpa Nagar, Nagaram Municipality, Keesara Mandal, Medchal - Malkajgiri District on 28.06.2025 and on the basis of Water Test Report (Attached) bearing Sample Report No. MPTRI/W/1001-287/1, Dated: 27.06.2025, from MPTRI, Kukatpally, Hyd certified that the St. Martin's School has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid for a period of One year from date of issue.

To
The Principal,
St. Martin's School,
Sy.No: 243, Shilpa Nagar,
Nagaram Municipality,
Keesara Mandal,
Medchal Malkajgiri District.


District Medical & Health Officer
Medchal Malkajgiri District
Medchal Dist., Telangana



Microbiology Testing Laboratory

An ISO 9001:2015 Certified Company

Aleap Common Facilities Area,
Survey No. 342, Aleap Industrial Estate,
Near Pragathi Nagar, Opp.JNTU Lane,
Kukatpally, Hyderabad - 500 072.

Mobile : 98485 94359, 96666 91334

Website : www.mptari.com

E-mail : mptari@gmail.com, mptari@rediffmail.com

TEST REPORT

Issued to:
M/s. St. Martin's School,
Sy No: 243, Shilpa Nagar, Nagaram Municipality,
Keesara (Mdl), Medchal-Malkajgiri (DT), Telangana.

Report No.: MPTRI/W/1001-287/1
Issue Date: 27th June, 2025
Customer Ref.: Nil
Ref. Date : 23rd June, 2025

Sample Particulars: RO Water

Qty.: 1 X 1000 ml. Type of Packing: Sterilized Bottles. Test Reqd.: Important Parameters
Date of starting of analysis: 23rd June, 2025 Date of completion of analysis: 27th June, 2025

TEST RESULTS

Essential Characteristics	Units	Result	Desirable Limits as per IS:10500
Colour	Hazen, Max	<1.0	5.0
Odour		Agreeable	Agreeable
Taste		Agreeable	Agreeable
Turbidity	NTU, Max	<1.0	1.0
pH	--	6.73	6.50-8.50
Total Hardness (as CaCO ₃)	mg/l, Max	20	200
Iron (as Fe)	mg/l, Max	<0.01	1.0
Chloride (as Cl)	mg/l, Max	18.14	250
Fluoride (as F)	mg/l, Max	<0.1	1.0
Desirable Characteristics			
Dissolved Solids	mg/l, Max	60	500
Calcium (as Ca)	mg/l, Max	14.02	75
Magnesium (as Mg)	mg/l, Max	0.50	30
Copper (as Cu)	mg/l, Max	<0.01	0.05
Manganese (as Mn)	mg/l, Max	<0.01	0.1
Sulphate (as SO ₄)	mg/l, Max	0.72	200
Nitrate (as NO ₃)	mg/l, Max	<0.01	45
Alkalinity	mg/l, Max	25	200
Aluminum (as Al)	mg/l, Max	<0.01	0.03
Bacteriological Characteristics			
Coliforms/100ml	CFU	Absent	Absent
E.coli/100ml	CFU	Absent	Absent

Remarks: The above analyzed test results are in the Desirable limits as per Drinking water specification IS: 10500-2012.

Swathi
SWATHI
AUTHORISED SIGNATORY